

THESE CONDUCTORS MUST BE AT LEAST 10 FEET FROM THE GROUND AND 18 INCHES LONG FOR MAKING CONNECTIONS.

WEATHER HEAD

5' MINIMUM

POLE

12' MINIMUM

METER SOCKET

GROUND WIRE - #6 COPPER OR LARGER

MOBILE HOME

SUGGESTED WIRING

| SERVICE SIZE | CONDUIT SIZE | CONDUCTOR SIZE |
|--------------|--------------|----------------|
| 100 AMP      | 1 1/4"       | #2 THW         |
| 150 AMP      | 1 1/2"       | #1/0 THW       |
| 200 AMP      | 2"           | #3/0 THW       |

5'

CONDUIT

GROUND LEVEL

18"

METER POLE FOR MOBILE HOME

4'

TALLAHATCHIE VALLEY ELECTRIC POWER ASSOCIATION

8 FOOT GROUND ROD

DATE: 1/24/92

DRAWN BY: RFD

MP-1

REVISED: 8/4/94

